

Catalog No. TQD225F

Description: ENCLSOURE NEMA 1 FLUSH 225A

UPC No 783164021240

Home > Circuit Breakers > Circuit Breaker Enclosures

GE's circuit breaker enclosures are UL Listed, CSA Certified and are suitable for use as service equipment (except as noted). The short circuit rating of the enclosure/circuit breaker combination is equal to the short circuit rating of the installed circuit breaker.

Frame notes and/or restrictions:TQD, THQD (2, 3 Pole)

ACCESSORIES:

Neutral Kit (non-GF applications):included

Descriptors	
Category	Circuit Breaker Enclosures
GO Schedule	B3

Specifications	
Enclosure Type	NEMA Type 1
Mounting	Flush
Frame Type	Q-Line
Amperage	225 A
Material	Steel
GSA Compliance	No

Classifications	
UL/CUL Listing	CSA UL

Dimensions	
Height	26.4 in
Depth Width	5.5 in
Width	8.9 in
Weight	16.4 lb



Created on: 11/03/2023

electrification.us.abb.com

electrification.us.abb.com Created on: 11/03/2023