




1492-JDG3C					1492-JDG4				1492-JDG4C			
Dimensions are not intended to be used for manufacturing purposes. Note: Height dimension is measured from top of rail to top of terminal block.												
Specifications	Two-level grounding terminal block with commoning bar				Two-circuit terminal block with one feed-through and one grounding				Two-level grounding terminal block with commoning bar			
Certifications		CSA	IEC	ATEX		CSA	IEC	ATEX		CSA	IEC	ATEX
Voltage Rating	—				600V AC/DC	300V AC/DC	800V AC/DC	550V AC/DC	—			
Maximum Current	Grounding				35 A	30 A	32 A	28 A	Grounding			
Wire Range (Rated Cross Section)	#22...12 AWG	#26...12 AWG	2.5 mm ²	2.5 mm ² (#20...14 AWG)	#26...10 AWG		4 mm ²	4 mm ²	#26...10 AWG	4 mm ²	4 mm ²	
Wire Strip Length	0.39 in. (10 mm)				0.31 in. (8 mm)				0.31 in. (8 mm)			
Recommended Tightening Torque	4.5...7.1 lb•in (0.5...0.8 N•m)				4.5...8.8 lb•in (0.5...1.0 N•m)				4.5...8.8 lb•in (0.5...1.0 N•m)			
Mounting Torque — Center Screw	—				—				—			
Density	59 pcs/ft (196 pcs/m)				49 pcs/ft (163 pcs/m)				49 pcs/ft (163 pcs/m)			
Housing Temperature Range	-58...+248 °F (-50...+120 °C)				-58...+248 °F (-50...+120 °C)				-58...+248 °F (-50...+120 °C)			
Short-Circuit Current Rating												
Terminal Blocks	Cat. No.			Pkg Qty.	Cat. No.			Pkg Qty.	Cat. No.			Pkg Qty.
Color: Green/Yellow	1492-JDG3C			100	—			—	1492-JDG4C			100
Grey	—			—	1492-JDG4			100	—			—
Accessories	Cat. No.			Pkg Qty.	Cat. No.			Pkg Qty.	Cat. No.			Pkg Qty.
Mounting Rails:												
1 m Symmetrical DIN (Steel)	199-DR1			10	199-DR1			10	199-DR1			10
1 m Symmetrical DIN (Aluminum)	1492-DR5			10	1492-DR5			10	1492-DR5			10
1 m Hi-Rise Sym. DIN (Aluminum)	1492-DR6			2	1492-DR6			2	1492-DR6			2
1 m Angled Hi-Rise Sym. DIN (Steel)	1492-DR7			2	1492-DR7			2	1492-DR7			2
Screw Type 1 m Symmetrical Heavy Duty DIN (Copper, Unslotted)	—			—	—			—	—			—
End Barrier Grey	1492-EBJD4			20	1492-EBJD4			20	1492-EBJD4			20
Yellow	1492-EBJD4-Y			20	1492-EBJD4-Y			20	1492-EBJD4-Y			20
Jumpers:												
Screw Center Jumper — 41-pole	—			—	1492-CJLJ6-41			10	—			—
Center Jumper — 10-pole	—			—	1492-CJLJ6-10			20	—			—
Center Jumper — 4-pole	—			—	1492-CJLJ6-4			60	—			—
Center Jumper — 3-pole	—			—	1492-CJLJ6-3			60	—			—
Center Jumper — 2-pole	—			—	1492-CJLJ6-2			60	—			—
End Anchors and Retainers:												
Screwless End Retainer	1492-ERL35			20	1492-ERL35			20	1492-ERL35			20
DIN Rail — Normal Duty	1492-EAJ35			100	1492-EAJ35			100	1492-EAJ35			100
DIN Rail — Heavy Duty	1492-EAHJ35			50	1492-EAHJ35			50	1492-EAHJ35			50
Marking Systems:												
Snap-in marker cards	1492-M5X8 (144/card)			5	1492-M6X5 (200/card)			5	1492-M6X5 (200/card)			5
Snap-in marker cards	1492-M5X5 (200/card)			5	1492-MR6X8 (120/card)			5	1492-MR6X8 (120/card)			5

Maximum number of multiple wire connections for copper conductors of the same cross-section and type for Allen-Bradley IEC Terminal Blocks. Cat. Nos. 1492-J and L products are all recommended for one conductor per terminal. Wire range is defined in the cat. page for each of the products.

In general, accessories for terminal blocks are not eligible for recognition by UL, CSA, or other third party approval agencies. The suitability of the installation must be judged in the end use application due to the wide variety of possible uses. However, accessories are designed to meet, and are tested to, the terminal block assembly requirements such as electrical spacings, etc.

Cat. No.	Wire Size [AWG]																		
	#30	#28	#26	#24	#22	#20	#18	#16	#14	#12	#10	#8	#6	#4	#2	#1	1/0	2/0	3/0
	Number of the Same Size Wires Per Terminal																		
1492-CA1	—	—	—	—	4	4	4	3	2	2	1	1	—	—	—	—	—	—	—
1492-CAM1	—	—	—	—	4	4	4	3	2	2	1	1	—	—	—	—	—	—	—
1492-H4	1	1	1	1	4	4	3	2	2	1	1	—	—	—	—	—	—	—	—
1492-H5	1	1	1	1	4	4	3	2	2	1	1	—	—	—	—	—	—	—	—
1492-H6	1	1	1	1	4	4	3	2	2	1	1	—	—	—	—	—	—	—	—
1492-H7	1	1	1	1	4	4	3	2	2	1	1	—	—	—	—	—	—	—	—
1492-HM3	—	—	—	—	4	4	4	3	2	2	1	1	—	—	—	—	—	—	—
1492-J10	—	—	—	—	4	4	4	4	3	2	1	1	1	—	—	—	—	—	—
1492-J16	—	—	—	—	—	—	1	4	4	3	2	1	1	1	—	—	—	—	—
1492-J2Q	—	—	4	4	4	3	1	1	1	1	—	—	—	—	—	—	—	—	—
1492-J3	4	4	4	4	4	4	3	3	2	1	—	—	—	—	—	—	—	—	—
1492-J35	—	—	—	—	—	—	—	—	3	3	3	2	2	1	1	1	1	—	—
1492-J3F	4	4	4	4	4	4	3	3	2	1	—	—	—	—	—	—	—	—	—
1492-J3P	4	4	4	4	3	3	3	3	2	1	—	—	—	—	—	—	—	—	—
1492-J3TW (single side)	4	4	4	4	4	4	3	3	2	1	—	—	—	—	—	—	—	—	—
1492-J3TW (twin side)	—	—	4	4	4	3	1	1	1	—	—	—	—	—	—	—	—	—	—
1492-J4	—	—	—	—	4	4	3	3	2	1	1	—	—	—	—	—	—	—	—
1492-J4CTB	—	—	1	1	4	4	3	3	2	1	1	—	—	—	—	—	—	—	—
1492-J4Q	1	1	1	1	1	4	3	3	2	1	1	—	—	—	—	—	—	—	—
1492-J4TW	1	1	1	1	1	4	3	3	2	1	1	—	—	—	—	—	—	—	—
1492-J50	—	—	—	—	—	—	—	—	—	—	1	2	2	1	1	1	1	—	—
1492-J6	—	—	—	—	4	4	3	3	3	2	1	1	—	—	—	—	—	—	—
1492-J70	—	—	—	—	—	—	—	—	5	5	5	2	2	2	1	1	1	1	1
1492-JC3	—	—	4	4	4	3	1	1	1	1	—	—	—	—	—	—	—	—	—
1492-JD3	4	4	4	4	4	4	3	2	2	1	—	—	—	—	—	—	—	—	—
1492-JD3DF	4	4	4	4	4	4	3	2	2	1	—	—	—	—	—	—	—	—	—
1492-JD3DR	4	4	4	4	4	4	3	2	2	1	—	—	—	—	—	—	—	—	—
1492-JD3F	4	4	4	4	4	4	3	1	1	1	—	—	—	—	—	—	—	—	—
1492-JD3FB	4	4	4	4	4	4	3	3	2	1	—	—	—	—	—	—	—	—	—
1492-JD3PSS	—	—	—	—	4	4	3	2	1	1	—	—	—	—	—	—	—	—	—
1492-JD3PSSTP	—	—	—	—	4	4	3	2	1	1	—	—	—	—	—	—	—	—	—
1492-JD3PTP	—	—	—	—	4	4	3	2	1	1	—	—	—	—	—	—	—	—	—
1492-JD3RB***	4	4	4	4	4	4	3	2	2	1	—	—	—	—	—	—	—	—	—
1492-JD3RC001	4	4	4	4	4	4	3	2	2	1	—	—	—	—	—	—	—	—	—
1492-JD3SS	4	4	4	4	4	4	3	2	2	1	—	—	—	—	—	—	—	—	—
1492-JD4	—	—	1	1	1	4	3	3	2	1	1	—	—	—	—	—	—	—	—
1492-JD4C	—	—	1	1	1	4	3	3	2	1	1	—	—	—	—	—	—	—	—
1492-JDC3	4	4	4	4	4	4	3	2	2	1	—	—	—	—	—	—	—	—	—
1492-JDG3	4	4	4	4	4	4	3	2	2	1	—	—	—	—	—	—	—	—	—
1492-JDG3FB	4	4	4	4	4	4	3	3	2	1	—	—	—	—	—	—	—	—	—
1492-JDG3P	—	—	—	—	4	4	3	2	1	1	—	—	—	—	—	—	—	—	—
1492-JDG3PSS	—	—	—	—	4	4	3	2	1	1	—	—	—	—	—	—	—	—	—
1492-JDG3PSSTP	—	—	—	—	4	4	3	2	1	1	—	—	—	—	—	—	—	—	—
1492-JDG3PTP	—	—	—	—	4	4	3	2	1	1	—	—	—	—	—	—	—	—	—
1492-JDG4	—	—	1	1	1	4	3	3	2	1	1	—	—	—	—	—	—	—	—